

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	49 - Central Coast
School Name:	Wuikinuxv Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: No
	Date of last inspection N/A
	Date of next inspection: N/A
	Date and type of most recent maintenance:
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Open window when necessary
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade):
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: No
	Detail:
Other Relevant Information:	The school does not have HVAC system. Wuikinuxv Nation is responsible for heating system maintenance according to Local Education Agreement (LEA).
District Contact for any Questions:	Name:
	Phone Number:
	Email: jsaulnier@sd49.ca